

1- قائمة السلع وحدود التسليم

الطلبية المرقمة (1/م/س ج ن 2023/1) تجهيز ألواح ترسيب لموسبات الأفران لمعمل سممنت الكوفة ينتج سممنت مقاوم للأحراق

رقم الفقرة	وصف السلع	الكمية	الوحدة	مكان التسليم النهائي	الموعد المتوقع للتسليم	فترة التجهيز بالأيام
	<p>Supply the collecting plate to electric precipitator for kiln produce sulfur resistance cement(SRC): Electric precipitator (FLSmidth co.) information data :- Gas flow 10,000 m³/min Gas temperature 350 °c Atmospheric pressure 1000 mbar Casing Max. pressure plus/minus 300 mm WG Casing Max. temperature 400 °c Max. pressure drop flange to flange 15-20 mm WG Number of bus section per field 2 * Ø 2800 mm Dew point/water content 70 °c Dust inlet loading 50 g/Nm³ wet Dust outlet loading , required 150 mg/Nm³ dry</p>					
	<p>Collecting plate (FLSmidth Co.) type : H(suitable for sulfur resistance cement) Thickness = 1.5 mm High= 12435 mm Width=486 mm Material is (St-37-2) or (S 235-JR) Assembly anvil plate by rivet not welding . As attach drawing no. (6A)</p>	1000			بحدود 180 يوم تبدأ من تاريخ	
	<p>Warranty period: 6 months starting from warehouse entry & technical conformity.</p>					
	<p>Note(1):Material of collecting plate must be suitable For current operation condition (SRC). Note(2): kufa cement plant change phase of cement from OPC(ordinary Portland cement)to SRC (sulphate resistance cement) by old way (wet process). Note(3): All properties of above items as (FLS company origin). Note(4): All items above must be western origin.</p>					

م.م. قديم
 صفا حيا لوكو لوكو ووكو لوكو
 مديري التصنيع والمبيعات الكوفة
 11 19
 م.م. قديم
 صفا حيا لوكو لوكو ووكو لوكو
 مديري التصنيع والمبيعات الكوفة
 م.م. قديم
 صفا حيا لوكو لوكو ووكو لوكو
 مديري التصنيع والمبيعات الكوفة
 م.م. قديم
 صفا حيا لوكو لوكو ووكو لوكو
 مديري التصنيع والمبيعات الكوفة

1-list of goods and delivery schedule

Tender NO: (167/SOC-1/2023) supply the collecting plate to electric precipitator for kiln produce sulfur resistance cement (KUFA CEMENT PLANT)

Item No.	Goods Description	Quantity	Unit	Final Delivery Destination	Supplying Period (in days)	
					Estimated Delivery period	The proposed Delivery Period by Bidder (filled by Bidder)
1	<p>Supply the collecting plate to electric precipitator for kiln produce sulfur resistance cement(SRC): Electric precipitator (FLSmith co.) information data :- Gas flow 10,000 m³/min Gas temperature 350 °c Atmospheric pressure 1000 mbar Casing Max. pressure plus/minus 300 mm WG Casing Max. temperature 400 °c Max. pressure drop flange to flange 15-20 mm WG Number of bus section per field 2 * Ø 2800 mm Dew point/water content 70 °c Dust inlet loading 50 g/Nm³ wet Dust outlet loading , required 150 mg/Nm³ dry</p> <p>Collecting plate (FLSmith Co.) type : H(suitable for sulfur resistance cement) Thickness = 1.5 mm Height= 12435 mm Width=486 mm Material is (St-37-2) or (S 235 JR) Assembly anvil plate by rivet not welding . As attach drawing no. (6A)</p>	1000	No		Estimated Delivery period	About (180 Days) starting from :
	<p>Warranty period: 6 months starting from warehouse entry & technical conformity.</p> <p>Note(1): Material of collecting plate must be suitable for current operation condition (SRC). Note(2): kufa cement plant change phase of cement from OPC(ordinary Portland cement)to SRC (sulphate resistance cement) by old way (wet process). Note(3): All properties of above items as (FLS ,company origin). Note(4): All items above must be western origin.</p>					

11/19
 C.C.K

د.م. القاسم

صاحب حياطة
 مدير الصيانة

مستشار
 مدير الصيانة

المدير الفني
 مدير الصيانة

2

مدير الصيانة

2- Tender: (14T/SOC-1/2023) supply the collecting plate to electric precipitator for kiln produce sulfur resistance cement (KUFA CEMENT PLANT)

IT.NO	SPECIFICATION	QTY
	Supply the collecting plate to electric precipitator for kiln produce sulfur resistance cement(SRC): Electric precipitator (FLSmith co.) information data :- Gas flow 10,000 m ³ /min Gas temperature 350 °c Atmospheric pressure 1000 mbar Casing Max. pressure plus/minus 300 mm WG Casing Max. temperature 400 °c Max. pressure drop flange to flange 15-20 mm WG Number of bus section per field 2 * Ø 2800 mm Dew point/water content 70 °c Dust inlet loading 50 g/Nm ³ wet Dust outlet loading , required 150 mg/Nm ³ dry	
1	Collecting plate (FLSmith Co.) type : H(suitable for sulfur resistance cement) Thickness = 1.5 mm Height= 12435 mm Width=486 mm Material is (St-37-2) or (S 235 JR) Assembly anvil plate by rivet not welding . As attach drawing no. (6A)	1000
	Warranty period: 6 months starting from warehouse entry & technical conformity.	
	Note(1):Materiel of collecting plate must be suitable for current operation condition . Note(2): kufa cement plant change phase of cement from OPC(ordinary Portland cement)to SRC (sulphate resistance cement) by old way (wet process). Note(3): All properties of above items as (FLS .company origin). Note(4): All items above must be western origin.	

Handwritten signature and notes in Arabic script, including the number 11.

Handwritten signature and notes in Arabic script, including the number 11.

Handwritten signature and notes in Arabic script, including the number 11 and 19, and a stamp: "صاحب يوسف هادي مدير الصيانة الميكانيكية".

3- Drawing

Drawings List		
No. Of Drawing	Name Of Drawing	Purpose
1	6.A FOR COLLECTING PLATE	FOR COLLECTING PLATE

Handwritten signature and date: 17/11/2017

Handwritten signature and date: 17/11/2017

Handwritten signature and date: 17/11/2017

Handwritten signature and date: 17/11/2017

Handwritten signature and date: 19/11/2017
 م.م. القدم
 صاحب يوسف عبد
 مدير التسيانة البيكانيكية

Handwritten signature and date: 17/11/2017
 م.م. القدم
 مدير التسيانة البيكانيكية

4- Test And Engineering Inspection

The Following Tests And Engineering Inspection will be executed (Fill in the schedule of tests and engineering inspections)

List of Inspections and Tests	
Line Item No	
1.	Inspection certificate for metal type ,dimensions . (For kiln produce <u>sulfur resistance cement(SRC)</u>)
2.	Inspection free of defects , gaps & good finishes.

Handwritten signature and notes in Arabic script, including the date 11/12.

Handwritten signature and notes in Arabic script, including the date 11/12.

Handwritten signature and notes in Arabic script, including the date 11/12 and a circular stamp.

Handwritten signature and notes in Arabic script, including the date 11/12.

Handwritten signature and notes in Arabic script, including the date 11/12.